

सहायक अभियन्ता (द्वितीय)
कार्यालय अधिशासी अभियन्ता
निर्माण खण्ड-1, लो0नि0वि0, अलीगढ़

पत्रांक: 238/9c

दिनांक: 08/04/2021

सेवा में,


✓ मुख्य विकास अधिकारी,
अलीगढ़।

विषय :- विद्यालय भवन के सुरक्षा सम्बन्धी अनापत्ति प्रमाण पत्र के सम्बन्ध में।

संदर्भ :- मु0वि0अ0 जनसुनवाई दिवस क्रमांक-06 दिनांक 06.04.2021

महोदय

उपरोक्त विषयक संदर्भित पत्र के क्रम में अवगत कराना है कि Radiant Stars English School, PO Lodha Khair Road Aligarh का स्थलीय निरीक्षण किया गया। स्थलीय निरीक्षण एवं उपलब्ध कराये गये ड्राईंग एवं अभिलेखों के अनुसार स्कूल भवन का निर्माण वर्ष 2006-07 में किया गया। स्थलीय निरीक्षण में प्रथम दृष्टया विद्यालय भवन एन0बी0सी0-2005 में निहित गाईड लाइन के अनुसार है एवं भवन प्रथम दृष्टया सुरक्षित प्रतीत होता है।



सहायक अभियन्ता (द्वितीय)
निर्माण खण्ड-1, लो0नि0वि0,
अलीगढ़

पत्रांक: /

दिनांक:

प्रतिलिपि-

1. अवर अभियन्ता (प्रा0) निर्माण खण्ड-1, लो0नि0वि0, अलीगढ़ को सूचनार्थ प्रेषित।


Principal
Radiant Stars English School
(Affiliated to CBSE)
Khair Road, Aligarh

For Radiant Stars English School

Secretary

✓
सहायक अभियन्ता (द्वितीय)
निर्माण खण्ड-1, लो0नि0वि0,
अलीगढ़

ER. PRADEEP KUMAR VARSHNEY

AMIE(CIVIL)

(Structure Engineer, Valuer, Estimator)

- Govt Approved Valuer No F-4895
- Income Tax Valuer No-V-01/2007-08
- Chartered Engineer No- 77496/3
- Approved From A.D.A., Aligarh
- RVO Memb. NO.- IIV-RVF/OM/108/2020
- OBPA5 ID No- AM0774963/26072018



Office cum Residence:-

99-F, Bank Colony

Premier Nagar,

Near Param Shakti Mandir,

Aligarh-202001

Mob: - 9837052118

E.Mail:- archineerhd@gmail.com

Panel Valuer of: *LICHEL *PNB *BPCL *ICICI *BANK OF BARODA *UJJIVAN *SBI

TO WHOM IT MAY IN CONCERN

Pursuant to the request from the Director Sri Mahak Singhal of Radiant Star English School run by Rama Educational Welfare Society, I inspected for checking the stability of structure of building as per N.B.C.-2005 (National Building Code). The Site is situated at Aligarh-Khair Road, Aligarh and Construction work of building was done in the year -2006-07. A.D.A. Sanctioned No- 815/15 (2004-05), Dated- 13-12-2005.

Covered area of construction at lower ground floor portion is 960.00 Sqm , Upper Ground floor Covered area is 2560.00 Sqm and first floor Covered area is 2560.00 Sqm. Total covered of all floors is 7680.00 Sqm. Plot area of this School building is 9103.15 Sqm. School campus is situated on 120'0" wide Aligarh-Khair Road.

In the specification of building it is a R.C.C. Framed Structure, with walls & foundations are in Brick work in cement mortar Flooring is in C.C. Floor /Kota Stone. Slabs are R.C.C. .

There are numbers of extinguishers for fire safety purpose. Two Hose reels are provided near stairs. Overhead water tank fire tank is also provided at terrace. Fire Safety aspects have been provided for fire prevention and life safety.



Proper Lighting, Daylight utilization, Ventilation is provided in this building.
Water Supply, Sewage, Sanitary system (Including Solid Waste) is provided for
Health precaution purpose. Rain water Harvesting System is also provided.

Therefore it is to Certify that the Structural and foundation design of Buildings
of Radiant Star English School, satisfy requirements as stipulated in the relevant
INDIAN STANDARD CODES / NATIONAL BUILDING CODE-2005.

Above Building safe from heavy rains& Earthquakes. In my Opinion the
further life of building is approximately **Sixty Five Years.**

Date :- 19-03-2025



Er PRADEEP KUMAR VARSHNEY

STRUCTURAL ENGINEER